

<b>TESTING REPORT</b>		Report No : ERP-P2021-00001			
<b>PURPOSE</b> 1) Europe Energy Labelling and MEPS application for model <b>WH-ADF0309J3E5CM / CU-2WZ71YBE5</b> as per requirement of Lot1		Report Date : 25. Aug. 2021			
		Venue : PAPANADMY, Psychro L testing room			
		Approved	Checked	Checked	Draft
		<i>Y. Tazari</i>	<i>ftc</i>	<i>[Signature]</i>	<i>[Signature]</i>

**1 Test Sample**

Model Name	Samples
WH-ADF0309J3E5CM	1
CU-2WZ71YBE5	1

**2 Details / Ratings**

Brand	<b>Panasonic</b>		
Rated voltage / phase / frequency	230V 1 $\phi$	50Hz	
Type of heat pump	<input checked="" type="checkbox"/> air-to-water	<input type="checkbox"/> water-to-water	<input type="checkbox"/> brine-to-water
Temperature application	<input checked="" type="checkbox"/> 35°C	<input checked="" type="checkbox"/> 55°C	
Water flow	<input type="checkbox"/> Fixed	<input checked="" type="checkbox"/> Variable	
Water outlet temperature	<input type="checkbox"/> Fixed	<input checked="" type="checkbox"/> Variable	

**3 Details / Testing Conditions**

Test mode	<input type="checkbox"/> Cooling	<input checked="" type="checkbox"/> Heating
Test type	<input type="checkbox"/> Cooling capacity	<input checked="" type="checkbox"/> Thermostat off power
	<input checked="" type="checkbox"/> Heating capacity	<input checked="" type="checkbox"/> Standby power
	<input checked="" type="checkbox"/> Sound Power	
Test room type	<input type="checkbox"/> Calorimeter room	<input checked="" type="checkbox"/> Psychrometric room
	<input checked="" type="checkbox"/> Reverberation room	<input type="checkbox"/> Anechoic room
Test standard	EN 14511 EN 14825 EN 12102-1	

**4 The heating climate condition to declare**

	Average	Colder	Warmer
Rated heating Pdesign	35°C 7 kW	6 kW	7 kW
Rated SCOP /Rank	35°C 4.00 A++	3.61 A+	5.69 A+++
Tbivalent(heating)	35°C -10 °C	-15 °C	2 °C
Rated heating Pdesign	55°C 7 kW	6 kW	6 kW
Rated SCOP /Rank	55°C 3.20 A++	2.80 A+	3.69 A++
Tbivalent(heating)	55°C -7 °C	-15 °C	2 °C
Rated Sound power in heating	55°C indoor 41 dB	outdoor 69 dB	
Rated sound power accordance to EN 14825			61 dB

**5 Heating/(Average, 35°C) capacity test conditions**

	<u>Part load (A)</u>	<u>Part load (B)</u>	<u>Part load (C)</u>	<u>Part load (D)</u>
Supply voltage/frequency	230V 1 $\phi$ , 50Hz	←	←	←
Stabilization period (minutes)	Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes
Test period/ reading frequency (minutes)	3 hours / 10 second	3 hours / 10 second	70 minutes / 30 second	70 minutes / 30 second
Outdoor condition				
mean dry bulb ( $\pm 0.3$ K)	-7.01	1.98	7.00	12.02
max variation ( $\pm 1$ K)	0.05	0.03	0.04	0.05
mean wet bulb ( $\pm 0.4$ K)	-8.02	1.01	5.98	10.99
max variation ( $\pm 1$ K)	0.05	0.04	0.05	0.05
Water IN/OUT condition				
Water Out temperature, T <sub>out</sub>	°C 34.05	30.50	27.29	25.38
Water In temperature, T <sub>in</sub>	°C 29.02	25.22	25.56	23.27
Heating flow rate, q <sub>w</sub>	l/min 17.73	10.48	23.94	23.54

DISTRIBUTE:

QR-D6-00

Panasonic Corporation

TESTING REPORT		Report No : ERP-P2021-00001			
(cont)					
<b>5 Heating/(Average, 35°C) capacity test conditions</b>					
		<b>Part load (F)</b>	<b>TOL</b>		
Supply voltage/frequency		230V 1 $\phi$ , 50Hz	←		
Stabilization period (minutes)		Not less than 60 minutes	Not less than 60 minutes		
Test period/ reading frequency (minutes)		70 minutes / 30 second	70 minutes / 30 second		
Outdoor condition					
mean dry bulb ( $\pm 0.3$ K)		-10.05	-10.05		
max variation ( $\pm 1$ K)		0.33	0.33		
mean wet bulb ( $\pm 0.4$ K)		-11.02	-11.02		
max variation ( $\pm 1$ K)		0.33	0.33		
Water IN/OUT condition					
Water Out temperature, T <sub>out</sub> °C		35.02	35.02		
Water In temperature, T <sub>in</sub> °C		29.94	29.94		
Heating flow rate, q <sub>w</sub> l/min		20.27	20.27		
<b>6 Heating/(Average, 35°C) capacity test results</b>					
		<b>Part load (A)</b>	<b>Part load (B)</b>	<b>Part load (C)</b>	<b>Part load (D)</b>
Measured heating capacity	kW	6.226	3.859	2.890	3.457
Measured power input	kW	2.181	0.989	0.589	0.528
Measured COP	W/W	2.854	3.900	4.904	6.553
		<b>Part load (F)</b>	<b>TOL</b>		
Measured heating capacity	kW	7.181	7.181		
Measured power input	kW	2.760	2.760		
Measured COP	W/W	2.602	2.602		
<b>7 Heating/(Average, 55°C) capacity test conditions</b>					
		<b>Part load (A)</b>	<b>Part load (B)</b>	<b>Part load (C)</b>	<b>Part load (D)</b>
Supply voltage/frequency		230V 1 $\phi$ , 50Hz	←	←	←
Stabilization period (minutes)		Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes
Test period/ reading frequency (minutes)		70 minutes / 30 second	70 minutes / 30 second	70 minutes / 30 second	70 minutes / 30 second
Outdoor condition					
mean dry bulb ( $\pm 0.3$ K)		-7.02	1.96	6.98	12.01
max variation ( $\pm 1$ K)		0.05	0.09	0.05	0.05
mean wet bulb ( $\pm 0.4$ K)		-8.01	0.98	6.01	11.02
max variation ( $\pm 1$ K)		0.05	0.07	0.04	0.05
Water IN/OUT condition					
Water Out temperature, T <sub>out</sub> °C		51.97	41.96	36.03	32.04
Water In temperature, T <sub>in</sub> °C		43.96	35.47	31.48	29.07
Heating flow rate, q <sub>w</sub> l/min		11.06	8.35	8.20	15.47

DISTRIBUTE:

QR-D6-00

Panasonic Corporation

TESTING REPORT		Report No : ERP-P2021-00001			
(cont)					
<b>7 Heating/(Average, 55°C) capacity test conditions</b>					
	<u>Part load (F)</u>	<u>TOL</u>			
Supply voltage/frequency	230V 1 $\emptyset$ , 50Hz	←			
Stabilization period (minutes)	Not less than 60 minutes	Not less than 60 minutes			
Test period/ reading frequency (minutes)	70 minutes / 30 second	70 minutes / 30 second			
Outdoor condition					
mean dry bulb ( $\pm 0.3$ K)	-10.02	-10.02			
max variation ( $\pm 1$ K)	0.10	0.10			
mean wet bulb ( $\pm 0.4$ K)	-11.00	-11.00			
max variation ( $\pm 1$ K)	0.30	0.30			
Water IN/OUT condition					
Water Out temperature, T <sub>out</sub> °C	54.99	54.99			
Water In temperature, T <sub>in</sub> °C	47.83	47.54			
Heating flow rate, q <sub>w</sub> l/min	12.36	12.36			
<b>8 Heating/(Average, 55°C) capacity test results</b>					
	<u>Part load (A)</u>	<u>Part load (B)</u>	<u>Part load (C)</u>	<u>Part load (D)</u>	
Measured heating capacity kW	6.178	3.778	2.601	3.200	
Measured power input kW	2.887	1.195	0.666	0.587	
Measured COP W/W	2.140	3.161	3.902	5.451	
	<u>Part load (F)</u>	<u>TOL</u>			
Measured heating capacity kW	6.178	6.421			
Measured power input kW	2.887	3.560			
Measured COP W/W	2.140	1.804			
<b>9 Heating/(Warmer, 35°C) capacity test conditions</b>					
	<u>Part load (B)</u>	<u>Part load (C)</u>	<u>Part load (D)</u>	<u>Part load (F)</u>	
Supply voltage/frequency	230V 1 $\emptyset$ , 50Hz	←	←	←	
Stabilization period (minutes)	Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes	
Test period/ reading frequency (minutes)	3 hours / 10 second	70 minutes / 30 second	70 minutes / 30 second	70 minutes / 30 second	
Outdoor condition					
mean dry bulb ( $\pm 0.3$ K)	1.99	6.99	12.00	1.99	
max variation ( $\pm 1$ K)	0.05	0.04	0.04	0.05	
mean wet bulb ( $\pm 0.4$ K)	1.02	6.01	10.98	1.02	
max variation ( $\pm 1$ K)	0.05	0.05	0.04	0.05	
Water IN/OUT condition					
Water Out temperature, T <sub>out</sub> °C	35.00	30.96	26.86	35.00	
Water In temperature, T <sub>in</sub> °C	30.02	26.07	24.87	30.02	
Heating flow rate, q <sub>w</sub> l/min	20.05	12.84	24.83	20.05	

DISTRIBUTE:

QR-D6-00

Panasonic Corporation

TESTING REPORT		Report No : ERP-P2021-00001			
(cont)					
<b>9 Heating/(Warmer, 35°C) capacity test conditions</b>					
		<u>TOL</u>			
Supply voltage/frequency		230V 1ø , 50Hz			
Stabilization period (minutes)		Not less than 60 minutes			
Test period/ reading frequency (minutes)		70 minutes / 30 second			
Outdoor condition					
mean dry bulb (±0.3 K)		1.99			
max variation (±1 K)		0.05			
mean wet bulb (±0.4 K)		1.02			
max variation (±1 K)		0.05			
Water IN/OUT condition					
Water Out temperature, T <sub>ou</sub> °C		35.00			
Water In temperature, T <sub>in</sub> °C		30.02			
Heating flow rate, q <sub>w</sub> l/min		20.05			
<b>10 Heating/(Warmer, 35°C) capacity test results</b>					
		<u>Part load (B)</u>	<u>Part load (C)</u>	<u>Part load (D)</u>	<u>Part load (F)</u>
Measured heating capacity	kW	6.970	4.382	3.442	6.970
Measured power input	kW	2.147	0.849	0.462	2.147
Measured COP	W/W	3.246	5.159	7.451	3.246
		<u>TOL</u>			
Measured heating capacity	kW	6.970			
Measured power input	kW	2.147			
Measured COP	W/W	3.246			
<b>11 Heating/(Warmer, 55°C) capacity test conditions</b>					
		<u>Part load (B)</u>	<u>Part load (C)</u>	<u>Part load (D)</u>	<u>Part load (F)</u>
Supply voltage/frequency		230V 1ø , 50Hz	←	←	←
Stabilization period (minutes)		Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes
Test period/ reading frequency (minutes)		70 minutes / 30 second	70 minutes / 30 second	70 minutes / 30 second	70 minutes / 30 second
Outdoor condition					
mean dry bulb (±0.3 K)		2.03	7.02	12.01	2.03
max variation (±1 K)		0.05	0.04	0.04	0.05
mean wet bulb (±0.4 K)		1.02	6.03	11.02	1.02
max variation (±1 K)		0.03	0.06	0.05	0.03
Water IN/OUT condition					
Water Out temperature, T <sub>ou</sub> °C		55.08	45.87	35.17	55.08
Water In temperature, T <sub>in</sub> °C		47.01	39.18	32.35	47.01
Heating flow rate, q <sub>w</sub> l/min		10.65	8.17	15.77	10.65

TESTING REPORT		Report No : ERP-P2021-00001			
(cont)					
<b>11 Heating/(Warmer, 55°C) capacity test conditions</b>					
		<b>TOL</b>			
Supply voltage/frequency		230V 1ø , 50Hz			
Stabilization period (minutes)		Not less than 60 minutes			
Test period/ reading frequency (minutes)		70 minutes / 30 second			
Outdoor condition					
mean dry bulb (±0.3 K)		2.03			
max variation (±1 K)		0.05			
mean wet bulb (±0.4 K)		1.02			
max variation (±1 K)		0.03			
Water IN/OUT condition					
Water Out temperature, T <sub>out</sub> °C		55.08			
Water In temperature, T <sub>in</sub> °C		47.01			
Heating flow rate, q <sub>w</sub> l/min		10.65			
<b>12 Heating/(Warmer, 55°C) capacity test results</b>					
		<b>Part load (B)</b>	<b>Part load (C)</b>	<b>Part load (D)</b>	<b>Part load (F)</b>
Measured heating capacity	kW	5.994	3.814	3.098	5.994
Measured power input	kW	2.497	1.198	0.637	2.497
Measured COP	W/W	2.401	3.184	4.865	2.401
		<b>TOL</b>			
Measured heating capacity	kW	5.990			
Measured power input	kW	2.495			
Measured COP	W/W	2.401			
<b>13 Heating/(Colder, 35°C) capacity test conditions</b>					
		<b>Part load (A)</b>	<b>Part load (B)</b>	<b>Part load (C)</b>	<b>Part load (D)</b>
Supply voltage/frequency		230V 1ø , 50Hz	←	←	←
Stabilization period (minutes)		Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes
Test period/ reading frequency (minutes)		3 hours / 10 second	70 minutes / 30 second	70 minutes / 30 second	70 minutes / 30 second
Outdoor condition					
mean dry bulb (±0.3 K)		-7.03	1.99	6.98	12.00
max variation (±1 K)		0.05	0.05	0.04	0.05
mean wet bulb (±0.4 K)		-8.01	1.02	5.98	11.03
max variation (±1 K)		0.05	0.06	0.04	0.05
Water IN/OUT condition					
Water Out temperature, T <sub>out</sub> °C		30.03	27.17	25.69	25.55
Water In temperature, T <sub>in</sub> °C		25.07	25.85	24.03	23.67
Heating flow rate, q <sub>w</sub> l/min		10.46	24.43	24.66	24.67

TESTING REPORT		Report No : ERP-P2021-00001		
(cont)				
<b>13 Heating/(Colder, 35°C) capacity test conditions</b>				
	<u>Part load (F)</u>	<u>Part load (G)</u>	<u>TOL</u>	
Supply voltage/frequency	230V 1 $\phi$ , 50Hz	←	←	
Stabilization period (minutes)	Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes	
Test period/ reading frequency (minutes)	3 hours / 10 second	70 minutes / 30 second	3 hours / 10 second	
Outdoor condition				
mean dry bulb ( $\pm 0.3$ K)	-15.03	-15.03	-15.03	
max variation ( $\pm 1$ K)	0.04	0.04	0.04	
mean wet bulb ( $\pm 0.4$ K)	-	-	-	
max variation ( $\pm 1$ K)	-	-	-	
Water IN/OUT condition				
Water Out temperature, $T_{out}$ °C	32.02	32.02	32.02	
Water In temperature, $T_{in}$ °C	27.04	27.04	28.39	
Heating flow rate, $q_w$ l/min	14.01	14.01	14.01	
<b>14 Heating/(Colder, 35°C) capacity test results</b>				
	<u>Part load (A)</u>	<u>Part load (B)</u>	<u>Part load (C)</u>	<u>Part load (D)</u>
Measured heating capacity kW	3.621	2.249	2.854	3.240
Measured power input kW	1.181	0.454	0.462	0.374
Measured COP W/W	3.064	4.955	6.181	8.655
	<u>Part load (F)</u>	<u>Part load (G)</u>	<u>TOL</u>	
Measured heating capacity kW	4.863	4.863	3.547	
Measured power input kW	1.897	1.898	1.916	
Measured COP W/W	2.564	2.562	1.851	
<b>15 Heating/(Colder, 55°C) capacity test conditions</b>				
	<u>Part load (A)</u>	<u>Part load (B)</u>	<u>Part load (C)</u>	<u>Part load (D)</u>
Supply voltage/frequency	230V 1 $\phi$ , 50Hz	←	←	←
Stabilization period (minutes)	Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes
Test period/ reading frequency (minutes)	70 minutes / 30 second	70 minutes / 30 second	70 minutes / 30 second	70 minutes / 30 second
Outdoor condition				
mean dry bulb ( $\pm 0.3$ K)	-7.04	2.02	7.03	12.02
max variation ( $\pm 1$ K)	0.05	0.04	0.04	0.04
mean wet bulb ( $\pm 0.4$ K)	-8.02	1.02	6.02	11.02
max variation ( $\pm 1$ K)	0.05	0.06	0.06	0.04
Water IN/OUT condition				
Water Out temperature, $T_{out}$ °C	43.95	37.10	33.03	29.25
Water In temperature, $T_{in}$ °C	37.55	33.14	30.56	27.39
Heating flow rate, $q_w$ l/min	8.09	8.07	15.39	24.67

TESTING REPORT		Report No : ERP-P2021-00001		
(cont)				
<b>15 Heating/(Colder, 55°C) capacity test conditions</b>				
	<u>Part load (F)</u>	<u>Part load (G)</u>	<u>TOL</u>	
Supply voltage/frequency	230V 1 $\phi$ , 50Hz	←	←	
Stabilization period (minutes)	Not less than 60 minutes	Not less than 60 minutes	Not less than 60 minutes	
Test period/ reading frequency (minutes)	3 hours / 10 second	70 minutes / 30 second	3 hours / 10 second	
Outdoor condition				
mean dry bulb ( $\pm 0.3$ K)	-15.04	-15.04	-15.04	
max variation ( $\pm 1$ K)	0.05	0.05	0.05	
mean wet bulb ( $\pm 0.4$ K)	-	-	-	
max variation ( $\pm 1$ K)	-	-	-	
Water IN/OUT condition				
Water Out temperature, T <sub>ou</sub> °C	48.97	48.97	48.97	
Water In temperature, T <sub>in</sub> °C	41.07	41.07	41.06	
Heating flow rate, q <sub>w</sub> l/min	8.79	8.79	8.79	
<b>16 Heating/(Colder, 55°C) capacity test results</b>				
	<u>Part load (A)</u>	<u>Part load (B)</u>	<u>Part load (C)</u>	<u>Part load (D)</u>
Measured heating capacity kW	3.611	2.227	2.653	3.201
Measured power input kW	1.484	0.644	0.566	0.470
Measured COP W/W	2.434	3.459	4.684	6.807
	<u>Part load (F)</u>	<u>Part load (G)</u>	<u>TOL</u>	
Measured heating capacity kW	4.845	4.845	4.850	
Measured power input kW	2.616	2.616	2.622	
Measured COP W/W	1.852	1.852	1.850	
<b>17 Standby mode test conditions</b>				
	<u>HSB</u>	<u>HOFF</u>	<u>HCK</u>	
Outdoor condition				
mean dry bulb ( $\pm 0.3$ K)	12.02	←	12.00	
max variation ( $\pm 1$ K)	0.03	←	0.12	
mean wet bulb ( $\pm 0.4$ K)	10.99	←	11.00	
max variation ( $\pm 1$ K)	0.03	←	0.18	
Water IN/OUT condition				
Water Out temperature, T <sub>out</sub> °C	23.33	←	25.30	
Water In temperature, T <sub>in</sub> °C	23.27	←	25.22	
Heating flow rate, q <sub>w</sub> l/min	-	←	-	
Supply voltage (230V $\pm$ 1%) V	229.1 - 230.8	←	←	
Supply frequency ( 50Hz $\pm$ 1%) Hz	49.5 - 50.5	←	←	
Stabilization period (minutes)	Not less than 5			
Total Harmonic Distortion ( <0.2% ) %	0.1	←	←	
<b>18 Standby mode test results (35°C or 55°C which is worse)</b>				
Does this model have a crankcase heater function?		<b>YES</b>		
Measured standby power		(35°C)		
HSB passive standby power consumption, Standby mode		11.0 W		
HOFF passive standby power consumption, OFF mode		11.0 W		
HCK passive standby power consumption, crank-case heater		0.0 W		

**19 Thermostat off mode test conditions**

8. Jan. 2019

Outdoor condition		<b>HTO</b>
mean dry bulb (±0.3 K)		12.01
max variation (±1 K)		0.04
mean wet bulb (±0.4 K)		11.03
max variation (±1 K)		0.03
Water IN/OUT condition		
Water Out temperature, T <sub>out</sub>	°C	23.33
Water In temperature, T <sub>in</sub>	°C	23.27
Heating flow rate, q <sub>w</sub>	l/min	9.16
Supply voltage (230V± 1%)	V	229.1 - 230.8
Supply frequency ( 50Hz ± 1%)	Hz	49.5 - 50.5
Stabilization period (minutes)		Not less than 5
Total Harmonic Distortion ( <0.2% )	%	0.1

**20 Thermostat off mode test results (35°C or 55°C which is worse)**

Measured standby power **(35°C)**  
 HTO passive standby power consumption, thermostat off mode 41.0 W

**21 Heating sound power test conditions (55°C)**

**Full load**  
 230V 1ø 50Hz

Stabilization period (minutes) Not less than 60 minutes

Outdoor condition		
mean dry bulb (7°C ±0.3 K)		7.03
max variation (±1 K)		0.10
mean wet bulb (6°C ±0.4 K)		6.04
max variation (±1 K)		0.09
Water IN/OUT condition		
Water Out temperature, T <sub>out</sub>	°C	55.02
Water In temperature, T <sub>in</sub>	°C	47.05
Heating flow rate, q <sub>w</sub>	l/min	14.31

**22 Heating sound power test results (55°C)**

**indoor outdoor outdoor (EN 14825)**

Measured sound power level dB 41.0 68.3 60.1

Rated heat output (Prated)	Maximum Sound Power Level at (A7W55)		
	Indoor	outdoor	Judge
Prated ≤ 6kW	60	65	
6kW < Prated ≤ 12kW <span style="color: red;">➔</span>	65	70	OK
12kW < Prated ≤ 30kW	70	78	
30kW < Prated ≤ 70kW	80	88	

**23 Determination of ΣFi**

Air-to-Water Heat Pump  
 F(1) = 3 F(2) = 0  
 ΣFi = F(1) + F(2) = 3 %

**24 See Appendix A for calculations**

**25 Remarks**



## Performance Testing Data for SCOP (55°C) - Average

Condition	Outdoor air T (°C)	Part load ratio (%)	Part load (kW)	Water outlet temperature (°C)	Declared Capacity (kW)	COP at DC	Cc	Cru	COP at PL
E (TOL)	-10	100	7.00	55	6.4	1.80			1.80
A	-7	88	6.19	52	6.2	2.14	0.99	1.00	2.14
B	2	54	3.77	42	3.8	3.16	0.97	1.00	3.16
C	7	35	2.42	36	2.6	3.90	0.94	0.93	3.90
D	12	15	1.08	30	3.2	5.45	0.93	0.34	4.79
F (Tbiv)	-7	88	6.19	52	6.2	2.14			2.14

## WH-ADF0309J3E5CM

WH-UD09HE5-1	Bin j	Outdoor air temp. Tj	Hours hj	Part load ratio (%)	Heat demand Ph(tj) (kW)	Heating capacity of the heat pump (kW)	COP(Tj)	Electric back up heater elbu(Tj) (kW)	Annual heating demand hj*Ph(Tj) (kWh)	Annual power input with electrical back up heater (kWh)
	9	-22	0	146%	10.23	0.000	0.000	10.23	0	0
	10	-21	0	142%	9.96	0.000	0.000	9.96	0	0
	11	-20	0	138%	9.69	0.000	0.000	9.69	0	0
	12	-19	0	135%	9.42	0.000	0.000	9.42	0	0
	13	-18	0	131%	9.15	0.000	0.000	9.15	0	0
	14	-17	0	127%	8.88	0.000	0.000	8.88	0	0
	15	-16	0	123%	8.62	0.000	0.000	8.62	0	0
	16	-15	0	119%	8.35	0.000	0.000	8.35	0	0
	17	-14	0	115%	8.08	0.000	0.000	8.08	0	0
	18	-13	0	112%	7.81	0.000	0.000	7.81	0	0
	19	-12	0	108%	7.54	0.000	0.000	7.54	0	0
	20	-11	0	104%	7.27	0.000	0.000	7.27	0	0
TOL	21	-10	1	100%	7.00	6.421	1.804	0.58	7	4
	22	-9	25	96%	6.73	6.340	1.916	0.39	168	92
	23	-8	23	92%	6.46	6.259	2.028	0.20	149	76
A	24	-7	24	88%	6.19	6.178	2.140	0.00	149	69
F	25	-6	27	85%	5.92	5.911	2.254	0.00	160	71
	26	-5	68	81%	5.65	5.643	2.367	0.00	384	162
	27	-4	91	77%	5.38	5.375	2.480	0.00	490	198
	28	-3	89	73%	5.12	5.108	2.594	0.00	455	176
	29	-2	165	69%	4.85	4.840	2.707	0.00	800	295
	30	-1	173	65%	4.58	4.572	2.821	0.00	792	281
	31	0	240	62%	4.31	4.305	2.934	0.00	1034	352
	32	1	280	58%	4.04	4.037	3.047	0.00	1131	371
B	33	2	320	54%	3.77	3.769	3.161	0.00	1206	382
	34	3	357	50%	3.50	3.500	3.309	0.00	1250	378
	35	4	356	46%	3.23	3.231	3.457	0.00	1150	333
	36	5	303	42%	2.96	2.962	3.606	0.00	897	249
	37	6	330	38%	2.69	2.692	3.754	0.00	888	237
C	38	7	326	35%	2.42	2.423	3.902	0.00	790	202
	39	8	348	31%	2.15	2.154	4.080	0.00	750	184
	40	9	335	27%	1.88	1.885	4.258	0.00	631	148
	41	10	315	23%	1.62	1.615	4.436	0.00	509	115
	42	11	215	19%	1.35	1.346	45.600	0.00	289	63
D	43	12	169	15%	1.08	1.077	4.791	43.00	182	38
	44	13	151	12%	0.81	0.808	4.969	0.00	122	25
	45	14	105	8%	0.54	0.538	5.146	0.00	57	11
	46	15	74	4%	0.27	0.269	5.324	0.00	20	4
								<b>Σ</b>	<b>14459</b>	<b>4514</b>

$$Q_H = P_{\text{designh}} \times H_{HE}$$

$$= 14462 \text{ kWh}$$

$$SCOP_{\text{on}} = (\text{Annual heating demand}) / (\text{Annual power input with electrical back up heater})$$

$$= 3.203 \text{ W/W}$$

$$Q_{HE} = Q_H / SCOP_{\text{on}} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}$$

$$= 4522.3 \text{ kWh}$$

$$SCOP = Q_H / Q_{HE}$$

$$= 3.198 \text{ W/W}$$

$$\Sigma Fi = F(1) + F(2)$$

$$= 3 \%$$

$$\eta_{\text{is (Tested)}} = (100/CC) \times SCOP - \Sigma F(i)$$

$$= 125\% \quad \mathbf{A++}$$

	Standby power		
	Pxx	Hxx	
		Heating only	Reversible
TO	41	178	178
SB	11	0	0
OFF	11	3672	0
CK	0	3850	178

## MEPS -Heat

MEPS (26.09.2015~)		MEPS (26.09.2017~)	
Min $\eta_s$	Judge	Min $\eta_s$	Judge
100%	OK	110%	OK

(Labelled)

SCOP<sub>(rated)</sub> **3.20**Q<sub>HE</sub> **4524** $\eta_{\text{is (Rated)}}$ **125%** **A++**

Performance Testing Data for SCOP (35°C) - Average

Condition	Outdoor air T (°C)	Part load ratio (%)	Part load (kW)	Water outlet temperature (°C)	Declared Capacity (kW)	COP at DC	Cc	Cru	COP at PL
E (TOL)	-10	100	7.00	35	7.2	2.60			2.60
A	-7	88	6.19	34	6.2	2.85	0.98	0.99	2.85
B	2	54	3.77	30	3.9	3.90	0.96	0.98	3.90
C	7	35	2.42	27	2.9	4.90	0.93	0.84	4.84
D	12	15	1.08	24	3.5	6.55	0.92	0.31	5.59
F (Tbiv)	-10	100	7.00	35	7.2	2.60			2.60

Condition	Bin j	Outdoor air temp. Tj	Hours hj	Part load ratio (%)	Heat demand Ph(tj) (kW)	Heating capacity of the heat pump (kW)	COP(Tj)	Electric back up heater elbu(Tj) (kW)	Annual heating demand hj*Ph(Tj) (kWh)	Annual power input with electrical back up heater (kWh)
	9	-22	0	146%	10.23	0.000	0.000	10.23	0	0
	10	-21	0	142%	9.96	0.000	0.000	9.96	0	0
	11	-20	0	138%	9.69	0.000	0.000	9.69	0	0
	12	-19	0	135%	9.42	0.000	0.000	9.42	0	0
	13	-18	0	131%	9.15	0.000	0.000	9.15	0	0
	14	-17	0	127%	8.88	0.000	0.000	8.88	0	0
	15	-16	0	123%	8.62	0.000	0.000	8.62	0	0
	16	-15	0	119%	8.35	0.000	0.000	8.35	0	0
	17	-14	0	115%	8.08	0.000	0.000	8.08	0	0
	18	-13	0	112%	7.81	0.000	0.000	7.81	0	0
	19	-12	0	108%	7.54	0.000	0.000	7.54	0	0
	20	-11	0	104%	7.27	0.000	0.000	7.27	0	0
TOL / F	21	-10	1	100%	7.00	7.181	2.602	0.00	7	3
	22	-9	25	96%	6.73	6.852	2.686	0.00	168	63
	23	-8	23	92%	6.46	6.522	2.770	0.00	149	54
A	24	-7	24	88%	6.19	6.192	2.854	0.00	149	52
	25	-6	27	85%	5.92	5.923	2.970	0.00	160	54
	26	-5	68	81%	5.65	5.654	3.087	0.00	384	125
	27	-4	91	77%	5.38	5.385	3.203	0.00	490	153
	28	-3	89	73%	5.12	5.115	3.319	0.00	455	137
	29	-2	165	69%	4.85	4.846	3.435	0.00	800	233
	30	-1	173	65%	4.58	4.577	3.552	0.00	792	223
	31	0	240	62%	4.31	4.308	3.668	0.00	1034	282
	32	1	280	58%	4.04	4.038	3.784	0.00	1131	299
B	33	2	320	54%	3.77	3.769	3.900	0.00	1206	309
	34	3	357	50%	3.50	3.500	4.088	0.00	1250	306
	35	4	356	46%	3.23	3.231	4.276	0.00	1150	269
	36	5	303	42%	2.96	2.962	4.464	0.00	897	201
	37	6	330	38%	2.69	2.692	4.652	0.00	888	191
C	38	7	326	35%	2.42	2.423	4.839	0.00	790	163
	39	8	348	31%	2.15	2.154	4.990	0.00	750	150
	40	9	335	27%	1.88	1.885	5.140	0.00	631	123
	41	10	315	23%	1.62	1.615	5.291	0.00	509	96
	42	11	215	19%	1.35	1.346	5.442	0.00	289	53
D	43	12	169	15%	1.08	1.077	5.592	0.00	182	33
	44	13	151	12%	0.81	0.808	5.743	0.00	122	21
	45	14	105	8%	0.54	0.538	5.893	0.00	57	10
	46	15	74	4%	0.27	0.269	6.044	0.00	20	3
								<b>Σ</b>	14459	3604

$Q_H = P_{designh} \times H_{HE}$   
 $= 14462 \text{ kWh}$   
 $SCOP_{on} = (\text{Annual heating demand}) / (\text{Annual power input with electrical back up heater})$   
 $= 4.012 \text{ W/W}$   
 $Q_{HE} = Q_H / SCOP_{on} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}$   
 $= 3612.1 \text{ kWh}$   
 $SCOP = Q_H / Q_{HE}$   
 $= 4.004 \text{ W/W}$   
 $\Sigma Fi = F(1) + F(2)$   
 $= 3 \%$   
 $\eta_s (\text{Tested}) = (100/CC) \times SCOP - \Sigma Fi$   
 $= 157\% \quad \mathbf{A++}$

	Pxx	Standby power Hxx	
		Heating only	Reversible
TO	41	178	178
SB	11	0	0
OFF	11	3672	0
CK	0	3850	178

MEPS -Heat			
MEPS (26.09.2015~)		MEPS (26.09.2017~)	
Min $\eta_s$	Judge	Min $\eta_s$	Judge
100%	OK	110%	OK

(Labelled) SCOP<sub>(rated)</sub> **4.00**      Q<sub>HE</sub> **3614**       $\eta_s$  (Rated) **157%**      **A++**

Performance Testing Data for SCOP (55°C) - Warmer

Condition	Outdoor air T (°C)	Part load ratio (%)	Part load (kW)	Water outlet temperature (°C)	Declared Capacity (kW)	COP at DC	Cc	Cru	COP at PL
E (TOL)	2	100	6.00	55	0.0	0.00			0.00
A									
B	2	100	6.00	55	6.0	2.40	0.98	1.00	2.40
C	7	64	3.86	46	3.8	3.18	0.97	1.00	3.18
D	12	29	1.71	34	3.1	4.86	0.94	0.55	4.62
F (Tbiv)	2	100	6.00	55	6.0	2.40			2.40

Condition	Bin j	Outdoor air temp. Tj	Hours hj	Part load ratio (%)	Heat demand Ph(Tj) (kW)	Heating capacity of the heat pump (kW)	COP(Tj)	Electric back up heater elbu(Tj) (kW)	Annual heating demand hj*Ph(Tj) (kWh)	Annual power input with electrical back up heater (kWh)
	9	-22	0	271%	16.29	0.000	0.000	16.29	0	0
	10	-21	0	264%	15.86	0.000	0.000	15.86	0	0
	11	-20	0	257%	15.43	0.000	0.000	15.43	0	0
	12	-19	0	250%	15.00	0.000	0.000	15.00	0	0
	13	-18	0	243%	14.57	0.000	0.000	14.57	0	0
	14	-17	0	236%	14.14	0.000	0.000	14.14	0	0
	15	-16	0	229%	13.71	0.000	0.000	13.71	0	0
	16	-15	0	221%	13.29	0.000	0.000	13.29	0	0
	17	-14	0	214%	12.86	0.000	0.000	12.86	0	0
	18	-13	0	207%	12.43	0.000	0.000	12.43	0	0
	19	-12	0	200%	12.00	0.000	0.000	12.00	0	0
	20	-11	0	193%	11.57	0.000	0.000	11.57	0	0
	21	-10	0	186%	11.14	0.000	0.000	11.14	0	0
	22	-9	0	179%	10.71	0.000	0.000	10.71	0	0
	23	-8	0	171%	10.29	0.000	0.000	10.29	0	0
A	24	-7	0	164%	9.86	0.000	0.000	9.86	0	0
	25	-6	0	157%	9.43	0.000	0.000	9.43	0	0
	26	-5	0	150%	9.00	0.000	0.000	9.00	0	0
	27	-4	0	143%	8.57	0.000	0.000	8.57	0	0
	28	-3	0	136%	8.14	0.000	0.000	8.14	0	0
	29	-2	0	129%	7.71	0.000	0.000	7.71	0	0
	30	-1	0	121%	7.29	0.000	0.000	7.29	0	0
	31	0	0	114%	6.86	0.000	0.000	6.86	0	0
	32	1	0	107%	6.43	0.000	0.000	6.43	0	0
TOL / B	33	2	3	100%	6.00	5.994	2.401	0.00	18	7
	34	3	22	93%	5.57	5.566	2.557	0.00	123	48
	35	4	63	86%	5.14	5.139	2.714	0.00	324	119
	36	5	63	79%	4.71	4.712	2.871	0.00	297	103
	37	6	175	71%	4.29	4.284	3.027	0.00	750	248
C	38	7	162	64%	3.86	3.857	3.184	0.00	625	196
	39	8	259	57%	3.43	3.429	3.472	0.00	888	256
	40	9	360	50%	3.00	3.000	3.760	0.00	1080	287
	41	10	428	43%	2.57	2.571	4.048	0.00	1101	272
	42	11	430	36%	2.14	2.143	4.336	0.00	921	212
D	43	12	503	29%	1.71	1.714	4.625	0.00	862	186
	44	13	444	21%	1.29	1.286	4.913	0.00	571	116
	45	14	384	14%	0.86	0.857	5.201	0.00	329	63
	46	15	294	7%	0.43	0.429	5.489	0.00	126	23
								Σ	8015	2138

$Q_H = P_{designh} \times H_{HE}$

= 8016 kWh

SCOPon = (Annual heating demand) / (Annual power input with electrical back up heater)

= 3.748 W/W

$Q_{HE} = Q_H / SCOP_{on} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}$

= 2169.7 kWh

SCOP =  $Q_H / Q_{HE}$

= 3.695 W/W

$\Sigma FI = F(1) + F(2)$

= 3 %

$\eta_s (Tested) = (100/CC) \times SCOP - \Sigma FI$

= 145.0% A++

	Pxx	Standby power Hxx	
		Heating only	Reversible
TO	41	754	754
SB	11	0	0
OFF	11	4416	0
CK	0	5170	754

MEPS -Heat

MEPS (26.09.2015~)		MEPS (26.09.2017~)	
Min $\eta_s$	Judge	Min $\eta_s$	Judge
100%	OK	110%	OK

(Labelled)

SCOP<sub>(rated)</sub> 3.69

Q<sub>HE</sub> 2170

$\eta_s$  (Rated) 145% A++

## Performance Testing Data for SCOP (35°C) - Warmer

Condition	Outdoor air T (°C)	Part load ratio (%)	Part load (kW)	Water outlet temperature (°C)	Declared Capacity (kW)	COP at DC	Cc	Cru	COP at PL
E (TOL)	2	100	7.00	35	0.0	0.00			0.00
A									
B	2	100	7.00	35	7.0	3.25	0.98	1.00	3.25
C	7	64	4.50	31	4.4	5.16	0.95	1.00	5.16
D	12	29	2.00	26	3.4	7.45	0.91	0.58	7.00
F (Tbiv)	2	100	7.00	35	7.0	3.25			3.25

Condition	Bin j	Outdoor air temp. Tj	Hours hj	Part load ratio (%)	Heat demand Ph(tj) (kW)	Heating capacity of the heat pump (kW)	COP(Tj)	Electric back up heater elbu(Tj) (kW)	Annual heating demand hj*Ph(Tj) (kWh)	Annual power input with electrical back up heater (kWh)
	9	-22	0	271%	19.00	0.000	0.000	19.00	0	0
	10	-21	0	264%	18.50	0.000	0.000	18.50	0	0
	11	-20	0	257%	18.00	0.000	0.000	18.00	0	0
	12	-19	0	250%	17.50	0.000	0.000	17.50	0	0
	13	-18	0	243%	17.00	0.000	0.000	17.00	0	0
	14	-17	0	236%	16.50	0.000	0.000	16.50	0	0
	15	-16	0	229%	16.00	0.000	0.000	16.00	0	0
	16	-15	0	221%	15.50	0.000	0.000	15.50	0	0
	17	-14	0	214%	15.00	0.000	0.000	15.00	0	0
	18	-13	0	207%	14.50	0.000	0.000	14.50	0	0
	19	-12	0	200%	14.00	0.000	0.000	14.00	0	0
	20	-11	0	193%	13.50	0.000	0.000	13.50	0	0
	21	-10	0	186%	13.00	0.000	0.000	13.00	0	0
	22	-9	0	179%	12.50	0.000	0.000	12.50	0	0
	23	-8	0	171%	12.00	0.000	0.000	12.00	0	0
A	24	-7	0	164%	11.50	0.000	0.000	11.50	0	0
	25	-6	0	157%	11.00	0.000	0.000	11.00	0	0
	26	-5	0	150%	10.50	0.000	0.000	10.50	0	0
	27	-4	0	143%	10.00	0.000	0.000	10.00	0	0
	28	-3	0	136%	9.50	0.000	0.000	9.50	0	0
	29	-2	0	129%	9.00	0.000	0.000	9.00	0	0
	30	-1	0	121%	8.50	0.000	0.000	8.50	0	0
	31	0	0	114%	8.00	0.000	0.000	8.00	0	0
	32	1	0	107%	7.50	0.000	0.000	7.50	0	0
TOL / B	33	2	3	100%	7.00	6.970	3.246	0.00	21	6
	34	3	22	93%	6.50	6.476	3.629	0.00	143	39
	35	4	63	86%	6.00	5.982	4.012	0.00	378	94
	36	5	63	79%	5.50	5.488	4.394	0.00	347	79
	37	6	175	71%	5.00	4.994	4.777	0.00	875	183
C	38	7	162	64%	4.50	4.500	5.159	0.00	729	141
	39	8	259	57%	4.00	4.000	5.528	0.00	1036	187
	40	9	360	50%	3.50	3.500	5.897	0.00	1260	214
	41	10	428	43%	3.00	3.000	6.265	0.00	1284	205
	42	11	430	36%	2.50	2.500	6.634	0.00	1075	162
D	43	12	503	29%	2.00	2.000	7.003	0.00	1006	144
	44	13	444	21%	1.50	1.500	7.372	0.00	666	90
	45	14	384	14%	1.00	1.000	7.740	0.00	384	50
	46	15	294	7%	0.50	0.500	8.109	0.00	147	18
								<b>Σ</b>	9351	1613

$$Q_H = P_{\text{designh}} \times H_{HE}$$

$$= 9352 \text{ kWh}$$

$$SCOP_{\text{on}} = (\text{Annual heating demand}) / (\text{Annual power input with electrical back up heater})$$

$$= 5.796 \text{ W/W}$$

$$Q_{HE} = Q_H / SCOP_{\text{on}} + H_{\text{TO}} \times P_{\text{TO}} + H_{\text{SB}} \times P_{\text{SB}} + H_{\text{CK}} \times P_{\text{CK}} + H_{\text{OFF}} \times P_{\text{OFF}}$$

$$= 1644.4 \text{ kWh}$$

$$SCOP = Q_H / Q_{HE}$$

$$= 5.687 \text{ W/W}$$

$$\Sigma F_i = F(1) + F(2)$$

$$= 3 \%$$

$$\eta_s (\text{Tested}) = (100/CC) \times SCOP - \Sigma F(i)$$

$$= 224.0\% \quad \mathbf{A++}$$

## MEPS - Heat

MEPS (26.09.2015~)		MEPS (26.09.2017~)	
Min $\eta_s$	Judge	Min $\eta_s$	Judge
100%	OK	110%	OK

	Pxx	Standby power Hxx	
		Heating only	Reversible
TO	41	754	754
SB	11	0	0
OFF	11	4416	0
CK	0	5170	754

(Labelled)

SCOP<sub>(rated)</sub> **5.69**Q<sub>HE</sub> **1644** $\eta_s$  (Rated)**224%** **A+++**

## Performance Testing Data for SCOP (55°C) - Colder

Condition	Outdoor air T (°C)	Part load ratio (%)	Part load (kW)	Water outlet temperature (°C)	Declared Capacity (kW)	COP at DC	Cc	Cru	COP at PL
E (TOL)	-15	82	4.89	49	4.9	1.85			1.85
G	-15	82	4.89	49	4.8	1.85	0.98	1.00	1.85
A	-7	61	3.63	44	3.6	2.43	0.97	1.00	2.43
B	2	37	2.21	37	2.2	3.46	0.94	0.99	3.46
C	7	24	1.42	32	2.7	4.68	0.93	0.54	4.41
D	12	11	0.63	28	3.2	6.80	0.91	0.20	5.02
F (Tbiv)	-15	82	4.89	49	4.8	1.85			1.85

Condition	Bin j	Outdoor air temp. Tj	Hours hj	Part load ratio (%)	Heat demand Ph(Tj) (kW)	Heating capacity of the heat pump (kW)	COP(Tj)	Electric back up heater elbu(Tj) (kW)	Annual heating demand hj*Ph(Tj) (kWh)	Annual power input with electrical back up heater (kWh)	
TOL	9	-22	1	100%	6.00	0.000	0.000	6.00	6	6	
	10	-21	6	97%	5.84	0.000	0.000	5.84	35	35	
	11	-20	13	95%	5.68	0.000	0.000	5.68	74	74	
	12	-19	17	92%	5.53	0.000	0.000	5.53	94	94	
	13	-18	19	89%	5.37	0.000	0.000	5.37	102	102	
	14	-17	26	87%	5.21	0.000	0.000	5.21	135	135	
	15	-16	39	84%	5.05	0.000	0.000	5.05	197	197	
F / G	16	-15	41	82%	4.89	4.863	1.852	0.00	201	108	
	17	-14	35	79%	4.74	4.709	1.925	0.00	166	86	
	18	-13	52	76%	4.58	4.555	1.998	0.00	238	119	
	19	-12	37	74%	4.42	4.401	2.070	0.00	164	79	
	20	-11	41	71%	4.26	4.247	2.143	0.00	175	82	
	21	-10	43	68%	4.11	4.093	2.216	0.00	177	80	
	22	-9	54	66%	3.95	3.939	2.289	0.00	213	93	
	23	-8	90	63%	3.79	3.786	2.361	0.00	341	144	
	A	24	-7	125	61%	3.63	3.632	2.434	0.00	454	186
		25	-6	169	58%	3.47	3.474	2.548	0.00	587	230
26		-5	195	55%	3.32	3.316	2.662	0.00	647	243	
27		-4	278	53%	3.16	3.158	2.776	0.00	878	316	
28		-3	306	50%	3.00	3.000	2.890	0.00	918	318	
29		-2	454	47%	2.84	2.842	3.004	0.00	1290	430	
30		-1	385	45%	2.68	2.684	3.118	0.00	1033	331	
31		0	490	42%	2.53	2.526	3.232	0.00	1238	383	
B	32	1	533	39%	2.37	2.368	3.346	0.00	1262	377	
	33	2	380	37%	2.21	2.211	3.459	0.00	840	243	
	34	3	228	34%	2.05	2.053	3.649	0.00	468	128	
	35	4	261	32%	1.89	1.895	3.839	0.00	495	129	
	36	5	279	29%	1.74	1.737	4.028	0.00	485	120	
	37	6	229	26%	1.58	1.579	4.218	0.00	362	86	
C	38	7	269	24%	1.42	1.421	4.408	0.00	382	87	
	39	8	233	21%	1.26	1.263	4.531	0.00	294	65	
	40	9	230	18%	1.11	1.105	4.654	0.00	254	55	
	41	10	243	16%	0.95	0.947	4.778	0.00	230	48	
	42	11	191	13%	0.79	0.789	4.901	0.00	151	31	
D	43	12	146	11%	0.63	0.632	5.025	0.00	92	18	
	44	13	150	8%	0.47	0.474	5.148	0.00	71	14	
	45	14	97	5%	0.32	0.316	5.272	0.00	31	6	
	46	15	61	3%	0.16	0.158	5.395	0.00	10	2	
								<b>Σ</b>	14789	5281	

$$Q_H = P_{\text{designh}} \times H_{HE}$$

$$= 14790 \text{ kWh}$$

$$SCOP_{\text{on}} = (\text{Annual heating demand}) / (\text{Annual power input with electrical back up heater})$$

$$= 2.800 \text{ W/W}$$

$$Q_{HE} = Q_H / SCOP_{\text{on}} + H_{\text{TO}} \times P_{\text{TO}} + H_{\text{SB}} \times P_{\text{SB}} + H_{\text{CK}} \times P_{\text{CK}} + H_{\text{OFF}} \times P_{\text{OFF}}$$

$$= 5285.8 \text{ kWh}$$

$$SCOP = Q_H / Q_{HE}$$

$$= 2.798 \text{ W/W}$$

$$\Sigma F_i = F(1) + F(2)$$

$$= 3 \%$$

$$\eta_s (\text{Tested}) = (100 / CC) \times SCOP - \Sigma F(i)$$

$$= 109\% \quad \mathbf{A+}$$

	Pxx	Standby power	
		Hxx Heating only	Reversible
TO	41	106	106
SB	11	0	0
OFF	11	2208	0
CK	0	2314	106

## MEPS-Heat

MEPS (26.09.2015~)		MEPS (26.09.2017~)	
Min $\eta_s$	Judge	Min $\eta_s$	Judge
100%	OK	110%	NG

(Labelled)

SCOP<sub>(rated)</sub> **2.80**Q<sub>HE</sub> **5289** $\eta_s$  (Rated)**109%** **A+**

Performance Testing Data for SCOP (35°C) - Colder

Condition	Outdoor air T (°C)	Part load ratio (%)	Part load (kW)	Water outlet temperature (°C)	Declared Capacity (kW)	COP at DC	Cc	Cru	COP at PL
E (TOL)	-15	82	4.89	32	3.5	1.85			1.85
G	-15	82	4.89	32	4.9	2.56	0.98	1.00	2.56
A	-7	61	3.63	30	3.6	3.06	0.97	1.00	3.06
B	2	37	2.21	27	2.3	4.95	0.91	0.98	4.95
C	7	24	1.42	25	2.9	6.18	0.91	0.50	5.67
D	12	11	0.63	24	3.2	8.65	0.89	0.19	5.96
F (Tbiv)	-15	82	4.89	32	4.9	2.56			2.56

Condition	Bin j	Outdoor air temp. Tj	Hours hj	Part load ratio (%)	Heat demand Ph(Tj) (kW)	Heating capacity of the heat pump (kW)	COP(Tj)	Electric back up heater elbu(Tj) (kW)	Annual heating demand hj*Ph(Tj) (kWh)	Annual power input with electrical back up heater (kWh)	
TOL	9	-22	1	100%	6.00	0.000	0.000	6.00	6	6	
	10	-21	6	97%	5.84	0.000	0.000	5.84	35	35	
	11	-20	13	95%	5.68	0.000	0.000	5.68	74	74	
	12	-19	17	92%	5.53	0.000	0.000	5.53	94	94	
	13	-18	19	89%	5.37	0.000	0.000	5.37	102	102	
	14	-17	26	87%	5.21	0.000	0.000	5.21	135	135	
	15	-16	39	84%	5.05	0.000	0.000	5.05	197	197	
	F / G	16	-15	41	82%	4.89	4.863	2.562	0.00	201	78
		17	-14	35	79%	4.74	4.709	2.624	0.00	166	63
		18	-13	52	76%	4.58	4.555	2.687	0.00	238	89
19		-12	37	74%	4.42	4.401	2.750	0.00	164	59	
20		-11	41	71%	4.26	4.247	2.813	0.00	175	62	
21		-10	43	68%	4.11	4.093	2.876	0.00	177	61	
22		-9	54	66%	3.95	3.939	2.939	0.00	213	73	
A		23	-8	90	63%	3.79	3.786	3.002	0.00	341	114
		24	-7	125	61%	3.63	3.632	3.064	0.00	454	148
		25	-6	169	58%	3.47	3.474	3.274	0.00	587	179
	26	-5	195	55%	3.32	3.316	3.484	0.00	647	186	
	27	-4	278	53%	3.16	3.158	3.694	0.00	878	238	
	28	-3	306	50%	3.00	3.000	3.904	0.00	918	235	
	29	-2	454	47%	2.84	2.842	4.114	0.00	1290	314	
	30	-1	385	45%	2.68	2.684	4.324	0.00	1033	239	
	31	0	490	42%	2.53	2.526	4.535	0.00	1238	273	
	32	1	533	39%	2.37	2.368	4.745	0.00	1262	266	
B	33	2	380	37%	2.21	2.211	4.955	0.00	840	170	
	34	3	228	34%	2.05	2.053	5.098	0.00	468	92	
	35	4	261	32%	1.89	1.895	5.242	0.00	495	94	
	36	5	279	29%	1.74	1.737	5.386	0.00	485	90	
	37	6	229	26%	1.58	1.579	5.530	0.00	362	65	
C	38	7	269	24%	1.42	1.421	5.673	0.00	382	67	
	39	8	233	21%	1.26	1.263	5.731	0.00	294	51	
	40	9	230	18%	1.11	1.105	5.788	0.00	254	44	
	41	10	243	16%	0.95	0.947	5.845	0.00	230	39	
	42	11	191	13%	0.79	0.789	5.902	0.00	151	26	
D	43	12	146	11%	0.63	0.632	5.959	0.00	92	15	
	44	13	150	8%	0.47	0.474	6.017	0.00	71	12	
	45	14	97	5%	0.32	0.316	6.074	0.00	31	5	
	46	15	61	3%	0.16	0.158	6.131	0.00	10	2	
<b>Σ</b>									14789	4093	

$Q_H = P_{designh} \times H_{HE}$   
 $= 14790 \text{ kWh}$   
 $SCOP_{on} = (\text{Annual heating demand}) / (\text{Annual power input with electrical back up heater})$   
 $= 3.613 \text{ W/W}$   
 $Q_{HE} = Q_H / SCOP_{on} + H_{TO} \times P_{TO} + H_{SB} \times P_{SB} + H_{CK} \times P_{CK} + H_{OFF} \times P_{OFF}$   
 $= 4097.3 \text{ kWh}$   
 $SCOP = Q_H / Q_{HE}$   
 $= 3.610 \text{ W/W}$   
 $\Sigma Fi = F(1) + F(2)$   
 $= 3 \%$   
 $\eta_s (\text{Tested}) = (100/CC) \times SCOP - \Sigma Fi$   
 $= 141.0\% \text{ A++}$

	Pxx	Standby power Hxx	
		Heating only	Reversible
TO	41	106	106
SB	11	0	0
OFF	11	2208	0
CK	0	2314	106

MEPS -Heat			
MEPS (26.09.2015~)		MEPS (26.09.2017~)	
Min ηs	Judge	Min ηs	Judge
100%	OK	110%	OK

(Labelled) SCOP<sub>(rated)</sub> **3.61** Q<sub>HE</sub> **4101** η<sub>s</sub> (Rated) **141%** **A+**